

PhaseCop 2 Phase Sequence Indicator

3-348-846-03 2/5.09

Compliance with Equipment Standards

Fulfills building regulations set forth in DIN VDE 0413.

Phase Sequence Testing in 3-Phase Systems

Phase sequence is acquired by means of an electronic circuit. The direction of rotation is indicated by one of two directional arrows, each of which is equipped with an LED.

Testing for Phase Failure

An LED is provided for each phase which indicates whether or not the phase conductor is live.

Large Voltage and Frequency Ranges

The device can be used in all low-voltage systems.

Rugged Design

The device is capable of withstanding severe mechanical stressing. The connector cables are permanently attached to the device.





(

Applicable Regulations and Standards

	DIN EN 61557-7 VDE 0413-7	Electrical safety in low voltage distribution systems up to 1000 V a.c. and 1500 V d.c. – Equipment for testing, measuring or monitoring of protective measures – Part 7: Phase sequence		
	DIN EN 60529 DIN VDE 0470, part 1	Test instruments and test procedures – degrees of protection provided by enclosures (IP code)		
	DIN EN 61326-1 VDE 0843-20-1	Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements		

Nominal Ranges of Use

Voltage 90 ... 660 V / 3 ~ Frequency 45 ... 1000 Hz

Duty Cycle

90 ... 380 V / 3 ~ continuous 380 ... 660 V / 3 ~ max. 3 min.

Electrical Safety

Test voltage 6 kV Safety class II

Mechanical Design

Protection IP 50

Dimensions 70 x 105 x 38.5 mm

Weight 0.3 kg

Included

- 1 phase sequence indicator
- 3 permanently attached connector cables with contact-protected plugs
- 3 plug-in test probes
- 1 plug-in alligator clip

PhaseCop 2 Phase Sequence Indicator

Accessories

F801 ever-ready case

Order Information

	Designation	Туре	Article Number
ľ	Phase sequence indicator	PhaseCop 2	GTM5202000R0001
	Ever-ready case	F801	GTY3172070P01

Edited in Germany • Subject to change without notice • A pdf version is available on the Internet

